



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 10/13/09

Code 50.10.8.7-09R

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title Section R606.12 Seismic Requirements		Page 1
Proponent SW Indiana Builders and Officials	Title	
Address 2175 N Cullen Ave Evansville, IN 47715 Room 310, Civic Center Complex, Evansville, IN 47708		Phone 812-479-6026 & 812-436-7868
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
Delete Section and replace as follows: "The seismic requirements of this section shall apply to the design of above grade masonry walls and the construction of the above grade masonry elements located in SDC C and C1. Structures located in SDC C and C1 shall also comply with the requirements of R606.12.2. These requirements shall not apply to glass units conforming to Section R610, masonry veneer conforming to Section R703.7, or below grade masonry foundation walls conforming to Section R404."		
REASON		
This amendment is part of the Seismic Package supported by home builders and building officials in the area, and is consistent to the existing standards. <i>Fiscal impact: As this seismic package is parallel to existing standards, no impact is expected.</i>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		